



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1460	13-Sep-2001	Number 22	Issue date 29-Apr-2026	30-Apr-2027

Product designation

Brooks, Model EIB105TY, 9 Vdc non-user replaceable lithium battery, interconnectable, photoelectric smoke alarm

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Brooks Australia Pty
4 Pike Street, RYDALMERE, NSW, AUSTRALIA, 2116

Registrant

Brooks Australia Pty
4 Pike Street, RYDALMERE, NSW, AUSTRALIA, 2116

Producer

Ei Electronics
SHANNON, CO. CLARE, IRELAND

Conformance criteria and evaluation

The Brooks, Model EIB105TY, 9 Vdc non-user replaceable lithium battery, interconnectable, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786-1993, 'Smoke alarms' incl. Amdt 1 (April 1995) / Amdt 2 (December 1995).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Smoke alarms should only be interconnected within the confines of a single family living unit.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 1460	13-Sep-2001	Number 22	Issue date 29-Apr-2026	30-Apr-2027	Page 2 of 2

Producer's description

The Brooks, Model EIB105TY, 9 Vdc non-user replaceable lithium battery, interconnectable, photoelectric smoke alarm is a multiple station internally energised photoelectric smoke alarm that is intended for use in residential dwellings. The smoke alarm operates by the sounding of a peizo-sounder that provides an audible alarm signal when the smoke alarm senses smoke which exceeds the pre-determined alarm level threshold. When the smoke level drops below the alarm threshold level, the peizo-sounder is de-energised. A self test facility is also provided by means of a test button that electrically simulates the presence of smoke. When the test button is depressed, an alarm signal is emitted until the test button is released.

The smoke alarm is internally powered from a 9 Vdc battery (FDK Corporation model NC604, comprising 3 lithium/manganese model CR8.L cells). The battery has a specified service life of at least 10 years. Indication that the battery is at the end of its service life is provided by a brief sound (fault signal) from the peizo-sounder, approximately once every 40 seconds. This fault signal is given for a period of at least 7 days. The manufacturer recommends replacement of the smoke alarm when the battery has reached the end of its service life.

The Brooks, Model EIB105TY, smoke alarm include an interconnection feature for connection of up to 12 other compatible Brooks smoke alarm units. Installation of the smoke alarm is achieved by a single screw, which is accessed by opening the smoke alarm outer cover.

Technical specification

The following details are a representative extract of the technical specification for the Brooks, Model EIB105TY, 9 Vdc non-user replaceable lithium battery, interconnectable, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Light source:	Infra-red Light Emitting Diode
Sensing element:	Photoelectric assembly
Interconnection:	
Number of units:	12
Maximum length of cable:	250 metres
Maximum resistance between detectors:	50 Ohms
Operating temperature range:	5°C to 45°C
Size:	140 mm x 120 mm
Height:	65 mm