



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3129</b>	16-Feb-2017	Number 10	Issue date 7-Apr-2026	30-Apr-2027

## Product designation

**Ningbo Siterwell Electronics Co. Ltd, Model GS526E, 3 Vdc non-user replaceable lithium battery, silencing/hush facility, photoelectric smoke alarm**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Siterwell Electronics Co., Limited  
No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

## Registrant

Siterwell Electronics Co., Limited  
No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

### Producer

Siterwell Electronics Co., Limited  
No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

## Conformance criteria and evaluation

The Ningbo Siterwell Electronics Co. Ltd, Model GS526E, 3 Vdc non-user replaceable lithium battery, silencing/hush facility, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015).
2. CSIRO Technical Specification TS-007, Version 2: 27-Jul-2015, 'Evaluation for Conformity of smoke alarms to the requirements of AS 3786:2014'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kai Loh

Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3129</b>	16-Feb-2017	Number 10	Issue date 7-Apr-2026	30-Apr-2027

Page 2 of 2

## Producer's description

The Ningbo Siterwell Electronics Co. Ltd, Model GS526E, 3 Vdc non-user replaceable lithium battery, silencing/hush facility, photoelectric smoke alarm intended for use in domestic and residential dwellings.

This product operates according to the principle of light scattering. Inside the measuring chamber, which is protected against external light by a black plastic labyrinth, a light emitter and a light receiver are mounted so that no direct light from the emitter can reach the receiver while aerosol is absent in the chamber.

If smoke particles enter the measuring chamber, the light pulse from the light emitter will be scattered by the smoke particles and can thus reach the light receiver. The electronics assess the light incidence and will activate an alarm (both visual and audible) if a predetermined threshold value is exceeded.

The smoke alarm device has a built-in self-test and indicates an insufficient battery voltage by an audible signal every 40 seconds. Furthermore, the red LED flashes once every 40 seconds.

## Technical specification

The following details are a representative extract of the technical specification for the Ningbo Siterwell Electronics Co. Ltd, Model GS526E, 3 Vdc non-user replaceable lithium battery, silencing/hush facility, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description
Type	Ident.	
Model number	GS526E (Ref.: ST526E)	Photoelectric smoke alarm

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Sensor	Photoelectric
Power	Built-in 3 Vdc (CR123A) Lithium battery (battery not replaceable)
Operation current	< 8uA (standby) < 70mA (alarm)
Alarm volume	85 dB(A) at 3 meters
Alarm sensitivity	0.11 - 0.16 dB/m
Silence time	approx. 10 minutes
Smoke alarm device sound pattern:	ISO 8201
Dimensions (approx.)	Diameter 100 mm Height 34 mm

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3058/R2	Evaluation for conformity of the Ningbo Siterwell Model GS526E Photoelectric Smoke Alarm to the requirements of AS 3786:2014 +A1:2015 'Smoke Alarms using scattered light, transmitted light or ionization'	19-Dec-2016	CSIRO, Fire Systems and Acoustics, AU
Manual	GS526E (Ref.: ST526E) Version A	Smoke Alarm Device User Manual Model number: GS526E Ref: ST526E	8-Jun-2016	Ningbo Siterwell Electronics Co., Ltd., CN