



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3471</b>	12-Jun-2020	Number 7	Issue date 7-Apr-2026	30-Apr-2027

Page 1 of 3

## Product designation

**Detector Inspector, Model DI10YLI, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, photoelectric smoke alarm**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Detector Inspector Pty. Ltd.  
2-4 Emily Street, CARNEGIE, VIC, AUSTRALIA, 3163

## Registrant

Siterwell Electronics Co., Limited  
No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

### Producer

Siterwell Electronics Co., Limited  
No. 666 Qingfeng Road, JIANGBEI DISTRICT, NINGBO, ZHEJIANG PROVINCE, CHINA, 315000

## Conformance criteria and evaluation

The Detector Inspector, Model DI10YLI, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015).

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3471</b>	12-Jun-2020	Number 7	Issue date 7-Apr-2026	30-Apr-2027

Page 2 of 3

## Producer's description

The Detector Inspector, Model DI10YLI, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, photoelectric smoke alarm is intended for use in domestic and residential dwellings. The battery is not user replaceable.

The smoke alarm senses smoke using the photoelectric principle. An electric buzzer/horn provides an audible alarm signal when the smoke alarm senses smoke which exceeds a pre-determined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energized.

A self-test facility is provided by means of a button. If the button is depressed an alarm signal is emitted. The Detector Inspector Model DI10YLI Photoelectric Smoke Alarm also incorporates a 'silence button' feature. According to the manufacturer's instructions, pressing the silence button can temporarily quiet unwanted alarm for up to 10 minutes.

The Detector Inspector Model DI10YLI Photoelectric Smoke Alarm is fitted with a wireless communications interface for up to 40 devices.

The smoke alarm is circular in shape. It is approximately 114 mm in diameter with a height of 38 mm.

## Technical specification

The following details are a representative extract of the technical specification for the Detector Inspector, Model DI10YLI, 10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Assembly description
Type	Ident.	
Model	DI10YLI	10 year sealed (non-replaceable) lithium battery powered, silencing/hush facility, photoelectric smoke alarm

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Smoke sensing type:	Type A Photoelectric
Main power source:	3 Vdc LiMnO <sub>2</sub> battery (not replaceable and not rechargeable)
Battery list:	CR17450
Software version:	V2.0
Interconnectivity:	Wireless (up to 40 devices)
Operating temperature range:	0 °C to 45 °C
Operating humidity range:	≤ 93%
Alarm sound level:	85 dB at 3 metres minimum
Alarm condition:	Audible signal pattern (ISO 8201)
Silencing function:	Yes
Dimensions:	Ø114 mm × 38 mm (h)
Fixing method:	Screws
Mounting method:	Wall and ceiling

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3471</b>	12-Jun-2020	Number 7	Issue date 7-Apr-2026	30-Apr-2027
				Page 3 of 3

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3396/R1	Evaluation for Conformity of the Detector Inspector Model DI10YLI Photoelectric Smoke Alarm to the requirements of AS 3786:2014 +A1:2015	12-May-2020	CSIRO, Fire Systems Laboratory, AU
Document ref.	Manual DI10YLI - Final.pdf	Detector Inspector Smoke Alarm User Manual Model number: DI10YLI	2-Apr-2020	Siterwell Electronics Co., Limited, CN