



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 4013	18-Mar-2026	Number 1	Issue date 18-Mar-2026	30-Apr-2027

Product designation

GT Smoke Alarms, GT10+ series, 3 Vdc 10 year non-replaceable battery powered, hush facility, photoelectric smoke alarm

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

GT SMOKE ALARMS
22 Bexley Ave, BALMORAL, QLD, AUSTRALIA, 4171

Registrant

Wisualarm
1-3/F, Building A2, No. 28 Dongqiao Road, Dongzhou Street, Fuyang District, HANGZHOU, Zhejiang, CHINA, 311400

Producer

Wisualarm
1-3/F, Building A2, No. 28 Dongqiao Road, Dongzhou Street, Fuyang District, HANGZHOU, Zhejiang, CHINA, 311400

Conformance criteria and evaluation

The GT Smoke Alarms, GT10+ series, 3 Vdc 10 year non-replaceable battery powered, hush facility, photoelectric smoke alarm has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 3786:2014, 'Smoke alarms using scattered light, transmitted light or ionization' incl. Amdt 1 (27 August 2015) / Amdt 2 (30 October 2018).

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 4013	18-Mar-2026	Number 1	Issue date 18-Mar-2026	30-Apr-2027

Producer's description

The GT Smoke Alarms, GT10+ series, smoke alarms are low profile, circular styled, 3V self-contained smoke alarms intended for use in residential dwellings. The battery is not user replaceable.

The GT Smoke Alarms, GT10+ series, smoke alarms sense smoke using the photoelectric principle. An electric buzzer/horn provides an audible alarm signal when the smoke alarm sense smoke which exceeds a pre-determined level. When the smoke level drops below the alarm level, the buzzer/horn is de-energized.

A self-test facility is provided by means of a button. If the button is depressed an alarm signal is emitted. The GT Smoke Alarms, GT10+ series, smoke alarm also incorporates a 'silence button' feature. According to the manufacturer's instructions, pressing the silence button reduces the smoke sensitivity for approximately 9 minutes, at which time the smoke alarm automatically returns to normal operation.

The Model GT10+ is a standalone device with no interconnectable facility.

The Model GT10RF+ is fitted with wireless communication interface only. It can wirelessly interconnect up to 24 devices.

Technical specification

The following details are a representative extract of the technical specification for the GT Smoke Alarms, GT10+ series, 3 Vdc 10 year non-replaceable battery powered, hush facility, photoelectric smoke alarm and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description
Type	Ident.	
Model	GT10+	3 Vdc, 10 years sealed (non-replaceable and non-rechargeable) lithium battery powered, silencing/hush facility, extended temperature range, standalone photoelectric smoke alarm.
	GT10RF+	3 Vdc, 10 years sealed (non-replaceable and non-rechargeable) lithium battery powered, silencing/hush facility, extended temperature range, wireless interconnectable (up to 24 devices), photoelectric smoke alarm.

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

	GT10+	GT10RF+
Smoke sensing type:	Type A photoelectric	
Main power source:	3 Vdc lithium battery (not replaceable and non-rechargeable)	
Standby power:	N/A	
Battery list:	EVE CR123A	Huiderei CR123A
Software version:	V1.0	
Interconnectivity:	N/A	wireless (up to 24 devices)
Operating temperature range:	-10 °C to 55 °C	
Operating humidity range:	≤ 93% RH	
Alarm sound level:	85 dB at 3 metres minimum	
Alarm condition:	Audible signal pattern (ISO 7731)	
Silencing function:	Yes	
Dimensions:	Ø81.5 mm × 51.6 mm (h)	
Fixing method:	Screw fixing	
Mounting method:	Ceiling only	

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 4013	18-Mar-2026	Number 1	Issue date 18-Mar-2026	30-Apr-2027

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	CSBA0187/NR1B	Evaluation for Conformity of the GT Smoke Alarms, GT+ Series, Smoke Alarms to the requirements of AS 3786:2014 + A1:2015 + A2:2018	18-Mar-2026	CSIRO, Fire Systems Laboratory, AU
Manual	User Manual_GT10+.pdf	GT HIGH PERFORMANCE SMOKE ALARMS Photoelectric Smoke Alarm GT10+ User's Manual V1.0.1 1.2.51.32.23258-000 (User Manual_GT10+.pdf)	21-Oct-2025	GT SMOKE ALARMS, AU
	User Manual_GT10RF+.pdf	GT HIGH PERFORMANCE SMOKE ALARMS Wireless Interconnected Smoke Alarm GTRF10+ User's Manual V1.0.1 1.2.51.32.23263-000 (User Manual_GT10RF+.pdf)		